



April 14, 2014

Mr. David O. Kornegay
AmphiCoat – TeKONTROL, Inc.
711 W. Amelia St.
Orlando, FL 32805-1401

Re.: AmphiSeal, AmphiBond, and AmphiMesh Products

Mr. Kornegay:

Thank you for your letter of April 3, 2014 in reference to acceptance of the cementitious coating system described in the supplied literature and its use in Miami-Dade County.

Pursuant to the product specifications and safety datasheets submitted, if the cementitious coating system is applied on the exterior of a building and over an impact resistant substrate as described in section 1626 of the 2010 Florida Building Code, an approval from this office is not required. Qualification of the product for use on a project can be shown to the Building Official at time of permit through listing or labeling in conformance to ASTM C926 *Specification for Application of Portland Cement-based Plaster* or equivalent standard.

Similarly, any other use of the cementitious coating system for construction governed by the Florida Building Code will require performance evaluation/comparison to the specifications applicable to the particular use. I.E. EIFS systems or installation over non-deemed impact resistant substrates.

If you have any additional questions, please feel free to contact our office.

Sincerely,

A handwritten signature in blue ink, appearing to read "Jaime Gascon".

Jaime D. Gascon, P.E.
Product Control Section Supervisor